



# TECHNICAL BULLETIN

**Issue Date : January 10, 2000****Revised: February 5, 2013****No. 01-101-00**

## Air and Water Infiltration Multi-Rib

On October 15, 1999, McElroy Metal, Inc. tested its Multi-Rib Panel for air leakage and water penetration.

**TEST METHODS:**

Air Leakage: ASTM E1680-95, "Rate of Air Leakage Through Exterior Metal Roof Panel Systems"

Water Penetration: ASTM E1646-95, "Water Penetration of Exterior Metal Roof Panel Systems by Uniform Static Air Pressure Difference"

**TEST SPECIMEN:**

McElroy Metal, Inc. 26 Ga. Multi-Rib Roof Panel with 1" x 1/8" Tape Sealer at sidelaps. Panels were attached to purlins using #12-14 x 1-1/4 ZAC fasteners. Sidelaps were fastened at 20" OC with 1/4-14 Lap ZAC fasteners.

**TEST RESULTS:**

Specimen	Air Infiltration			Water Penetration			
	Static Pressure Differential (psf)	Air Infiltration rate (cfm/lf)	Air Infiltration rate (cfm/sf)	Static Pressure Differential (psf)	Rate (gal./hr/sf)	Test Duration (min)	Water Infiltration
Multi-Rib 26* Ga.	-6.24	0.007	0.002	12.0	5	15	None
Multi-Rib 26* Ga.	+6.24	0.004	0.001				
Multi-Rib 26* Ga.	-1.57	0.004	0.001				
Multi-Rib 26* Ga.	+1.57	0.000	0.000				

Test Report No. : T213-99

Dated : October 15, 1999

\*Test results are valid for heavier gauges or thicknesses.

**CORPORATE OFFICE  
SHREVEPORT, LOUISIANA**BOSSIER CITY, LA  
CLINTON, ILPEACHTREE CITY, GA  
MARSHALL, MIWINCHESTER, VA  
ADELANTO, CALEWISPORT, KY  
MAUSTON, WIASHBURN, GA  
MERKEL, TXSUNNYVALE, TX  
HOUSTON, TX