



TECHNICAL BULLETIN

Issue Date : February 29, 2000

Revised: February 5, 2013

No. 01-111-00

Air and Water Infiltration MasterLok-90 22 Ga.

On November 18, 1999, McElroy Metal, Inc. tested its MasterLok-90 Panel for air leakage and water penetration.

TEST METHODS:

Air Leakage: ASTM E1680-95, "Rate of Air Leakage Through Exterior Metal Roof Panel Systems"

Water Penetration: ASTM E1646-95, "Water Penetration of Exterior Metal Roof Panel Systems by Uniform Static Air Pressure Difference"

TEST SPECIMEN:

McElroy Metal, Inc. 22 Ga. 24 in. wide MasterLok-90 Roof Panel with 3/16" bead of Q-41-20 Robofoam Mastic Sealant at sidelaps. Panels were attached to purlins using 1/4-14 x 1-1/4 fasteners.

TEST RESULTS:

*Results are extrapolated to different panel widths

Specimen	Air Infiltration			Water Penetration			
	Static Pressure Differential (psf)	Air Infiltration rate (cfm/lf)	Air Infiltration rate (cfm/sf)	Static Pressure Differential (psf)	Rate (gal./hr/sf)	Test Duration (min)	Water Infiltration
ML-90 24 in. 22** Ga.	+/-6.24	0.003	0.001	12.00	5	15	None
ML-90 24 in. 22** Ga.	-1.57	0.003	0.001	12.00	5	15	None
ML-90 24 in. 22** Ga.	+ 1.57	0.000	0.000				
*ML-90 18 in. 22** Ga.	+/-6.24	0.003	0.002				
*ML-90 18 in. 22** Ga.	- 1.57	0.003	0.002	12.00	5	15	None
*ML-90 18 in. 22** Ga.	+ 1.57	0.000	0.000				

Test Report No. : T224-99

Dated : November 18, 1999

**Test results are valid for heavier gauges or thicknesses.

**CORPORATE OFFICE
SHREVEPORT, LOUISIANA**

BOSSIER CITY, LA
CLINTON, IL

PEACHTREE CITY, GA
MARSHALL, MI

WINCHESTER, VA
ADELANTO, CA

LEWISPORT, KY
MAUSTON, WI

ASHBURN, GA
MERKEL, TX

SUNNYVALE, TX
HOUSTON, TX