



TECHNICAL BULLETIN

Issue Date : March 29, 2000**Revised: February 5, 2013****No. 01-115-00**

Air and Water Infiltration Medallion II 24 Ga.

On January 3, 2000, McElroy Metal, Inc. tested its Medallion II Panel for air leakage and water penetration.

TEST METHODS:

Air Leakage: ASTM E1680-95, "Rate of Air Leakage Through Exterior Metal Roof Panel Systems"

Water Penetration: ASTM E1646-95, "Water Penetration of Exterior Metal Roof Panel Systems by Uniform Static Air Pressure Difference"

TEST SPECIMEN:

McElroy Metal, Inc. 24 Ga. 12 in. wide Medallion II Roof Panel over #30 underlayment with 6 inch overlaps. Panels were attached to 5/8" (nominal) plywood using (2) #10-12 Pancake Head woodgrip fastener per clip, with clips at 2 feet on center. All plywood butt joints were sealed with silicone sealant.

TEST RESULTS:

Specimen	Air Infiltration			Water Penetration			
	Static Pressure Differential (psf)	Air Infiltration rate (cfm/lf)	Air Infiltration rate (cfm/sf)	Static Pressure Differential (psf)	Rate (gal./hr/sf)	Test Duration (min)	Water Infiltration
Medallion II 12" 24* Ga.	+6.24	0.031	0.029	6.24	5	15	None
Medallion II 12" 24* Ga.	+1.57	0.014	0.013				
Medallion II 12" 24* Ga.	-6.24	0.019	0.017				
Medallion II 12" 24* Ga.	-1.57	0.012	0.011				

Test Report No. : T102-00

Dated : January 5, 2000

*Test results are valid for heavier gauges or thicknesses.

**CORPORATE OFFICE
SHREVEPORT, LOUISIANA**

BOSSIER CITY, LA
CLINTON, IL

PEACHTREE CITY, GA
MARSHALL, MI

WINCHESTER, VA
ADELANTO, CA

LEWISPORT, KY
MAUSTON, WI

ASHBURN, GA
MERKEL, TX

SUNNYVALE, TX
HOUSTON, TX