



TECHNICAL BULLETIN

Issue Date: July 18, 2008


Revised: January 2, 2014

No. 05-308-08

ASTM E1592 Wind Uplift Test

Medallion Lok 18" 24 Ga.

McElroy Metal had its Medallion Lok roof panel tested per ASTM E1592 between the dates of December 2, 2010 and April 23, 2012.



TEST RESULTS

Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 1.67 (AISI)
Medallion Lok 18"	24	1'-0"	107.5	64.4
Medallion Lok 18"	24	2'-0"	78.0	46.7
Medallion Lok 18"	24	5'-0"	45.1	27.0

Test Report: 10-004

Date: July 12, 2013

CORPORATE OFFICE
SHREVEPORT, LOUISIANA

BOSSIER CITY, LA
CLINTON, IL

PEACHTREE CITY, GA
MARSHALL, MI

WINCHESTER, VA
ADELANTO, CA

LEWISPORT, KY
MAUSTON, WI

ASHBURN, GA
MERKEL, TX

SUNNYVALE, TX
HOUSTON, TX