



# TECHNICAL BULLETIN

Issue Date: July 18, 2008


Revised: January 3, 2014

No. 05-309-08

## ASTM E1592 Wind Uplift Test

### Medallion Lok 18" 22 Ga.

McElroy Metal had its Medallion Lok roof panel tested per ASTM E1592 on dates between May 12, 2011 and December 1, 2011.



### TEST RESULTS

Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 1.67 (AISI)
Medallion Lok 18"	22	1'-0"	131.7	78.9
Medallion Lok 18"	22	2'-0"	121.3	72.6
Medallion Lok 18"	22	5'-0"	83.2	49.8

Test Report No.: 11-002

Dated: May 23, 2013

**CORPORATE OFFICE**  
**SHREVEPORT, LOUISIANA**

BOSSIER CITY, LA  
CLINTON, IL

PEACHTREE CITY, GA  
MARSHALL, MI

WINCHESTER, VA  
ADELANTO, CA

LEWISPORT, KY  
MAUSTON, WI

ASHBURN, GA  
MERKEL, TX

SUNNYVALE, TX  
HOUSTON, TX