



# TECHNICAL BULLETIN


Issue Date: December 12, 2014

No. 05-357-14

## ASTM E1592 Wind Uplift Test

### 238T 16" 20 oz. Copper

McElroy Metal tested its 238T structural standing seam panel per ASTM E1592 on September 25, 2013 and September 27, 2013.



### TEST RESULTS

Negative (uplift) loading				
Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 2.0 (AISI)
238T 16"	20 oz.	1'-0"	312.0	156.00
238T 16"	20 oz.	5'-0"	78.0	39.00

Test Report No. : 13-012

Dated: November 15, 2013

**CORPORATE OFFICE**  
**SHREVEPORT, LOUISIANA**

BOSSIER CITY, LA  
CLINTON, IL

PEACHTREE CITY, GA  
MARSHALL, MI

WINCHESTER, VA  
ADELANTO, CA

LEWISPORT, KY  
MAUSTON, WI

ASHBURN, GA  
MERKEL, TX

SUNNYWALE, TX  
HOUSTON, TX