



TECHNICAL BULLETIN


Issue Date : January 17, 2007

No. 05-278-07

ASTM E1592 Wind Uplift Test

MarqueeLok 22 Ga.

McElroy Metal had its MarqueeLok structural soffit panel tested per ASTM E1592 on February 14, 2006, June 6, 2006 and June 8, 2006. This test meets the guide specs of CEGS 07416, and therefore, can be specified for use on military projects.



TEST RESULTS

| Panel | Gauge | Span | Ultimate Load (psf) | Design Load (psf) Factor of Safety = 1.65 (CEGS) | Design Load (psf) Factor of Safety = 2.00 (AISI) |
|------------|-------|--------|---------------------|--|--|
| MarqueeLok | 22 | 1'-0" | 213.2 | 129.2 | 106.6 |
| MarqueeLok | 22 | 5'-0" | 104.0 | 63.0 | 52.0 |
| MarqueeLok | 22 | 7'-11" | 52.0 | 31.5 | 26.0 |

Test Report No. : 06-005

Dated : December 27, 2006

CORPORATE OFFICE
SHREVEPORT, LOUISIANA