



TECHNICAL BULLETIN

Issue Date : August 20, 2002


Revised: December 15, 2010

No. 05-150-02

ASTM E1592 Wind Uplift Test

MedallionLok 16” 22 Ga.

McElroy Metal had its MedallionLok structural standing seam panel tested per ASTM E1592 between the dates of March 26, 2010 and October 21, 2010.



TEST RESULTS

Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 1.67
MedallionLok 16"	22	1'-0"	164.67	98.60
MedallionLok 16"	22	2'-0"	149.07	89.26
MedallionLok 16"	22	5'-0"	89.27	53.46

Test Report No. : 10-002

Dated : October 22, 2010

CORPORATE OFFICE
SHREVEPORT, LOUISIANA