



TECHNICAL BULLETIN

Issue Date: July 7, 2002

Revised April, 6, 2010

No. 05-149-02

ASTM E1592 Wind Uplift Test

Medallion-Lok 16” 24 Ga.

McElroy Metal had its Medallion-Lok structural standing seam panel tested per ASTM E1592 between the dates of January 7, 2010 and March 19, 2010.



TEST RESULTS

Panel	Gauge	Span	Ultimate Load (psf)	Design Load (psf) Factor of Safety = 1.67 (AISI*)
Medallion-Lok 16"	24	1'-0"	116.13	69.54
Medallion-Lok 16"	24	2'-0"	88.40	52.93
Medallion-Lok 16"	24	5'-0"	50.27	30.10

Test Report No.: 10-001

Dated: April 6, 2010

CORPORATE OFFICE
SHREVEPORT, LOUISIANA