



TECHNICAL BULLETIN


Issue Date: June 7, 2010

No. 09-312-10

ASTM E2140 Water Head Test

Maxima 218 24 Ga.

McElroy Metal had its Maxima structural standing seam panel tested per ASTM E2140 on February 28, 2007. These test results may be applied to the Maxima 216 and Maxima 212 both in 24 gauge and 22 gauge. The seam heights, panel clips, sealant type and sealant location are identical for these profiles.



TEST RESULTS

Time	Device 1	Device 2	Device 3	Device 4	Observations
0 hr	6"	6 1/8"	6"	6"	No Leaks Observed
1 hr	6"	6 1/8"	6"	6"	No Leaks Observed
3 hr	6"	6 1/8"	6"	6"	No Leaks Observed
6 hr	6"	6 1/8"	6"	6"	No Leaks Observed

Test Report No.: 07-001

Dated: January 27, 2006

CORPORATE OFFICE
SHREVEPORT, LOUISIANA